



Picton 33kV Dual Circuit Cross-Arm Replacement

Andrew McFarlane


Introduction

- Marlborough Lines
 - Operational Area/Statistics
- Picton 33kV Dual Supply Maintenance Needs
- Solution
 - Installation of Temporary Generator Farm
 - Protection & Synchronising
 - Other complexities




Marlborough Lines Network

- Marlborough Lines network 33kV, 11kV & 400V
 - Single Transpower GXP
 - Townships of Blenheim, Havelock, Picton etc
 - Down the East Coast beyond Clarence River
 - Down the Wairau & Awatere Valleys
 - Marlborough Sounds
- Approx. 3400km of network supplying 25k consumers
 - Rugged Remote Network
- Trust owned. MEPT holds shares on behalf of beneficiaries




Map of Picton feeder

- Picton is supplied by a dual 33kV circuit, diverse in Para area but share pole structures between Blenheim & Tuamarina.
- The original line between Blenheim and Picton was completed in 1950 as before that Picton ran off its own electricity supply from a water wheel and diesel generation, since decommissioned.
- On the Picton feeder there are 3,325 connections.




Picton 33kV Dual Circuit

- Upgraded in 1972
- Land impacts
 - Farming land prior to 1980s Vineyard Boom
- 47 Structures
- Supplies Spring Creek Zone Sub
 - 1220 Customers



Condition Assessment

- External Contractor
 - Asset Inspection Regime – 3 yearly
 - Ground Assessment Only
 - Moisture & UV
- Line Inspection Techniques
 - Aerial Drone Photography
 - Go Pro on Pokey Stick
 - Previously Removed Pole
- Poles and Steel Work ✓
- Crossarms X



Options?

- Needed to Act
- Line Rebuild/Replacement? - \$\$\$
- Replace the Arms
 - Steel and Polymer Clamp
 - Total outage? - +3k customers
 - Live Line Procedure? – 50 pole sites & Industry Trend
 - Isolate and supply all load from alternate source? ✓
 - Indicative pricing
 - Experience with diesel generation


Project Timeline

- When?
- External Contracting Resources – MLL+
- Access Restriction
 - Wet Ground
 - ‘Sauvalanche’ Grape Harvest – Late May.
- Winter Load
- Target Date:
 - 2nd – 6th May

Data - Load Considerations


- Generator Sizing Considerations
 - Picton Peak Load
 - Work Hours 8am-5pm
 - Load Growth
 - Winter Load Forecast – Buffer
- Market Reconciliation
- Fuel Consumption

Data - Load Considerations



Data - Load Considerations

Picton 10min Avg Load 1st-2nd May





6MW Diesel Generation Farm

- 6MW Diesel Gen Farm
 - 6x Containerised 400V
 - 800kVA – 1500kVA
 - N-1 Capacity
 - 1x ‘Six Pack’
 - 6xLV CB connections
 - 2x3.15MVA Dyn11 TXs
 - 22kV Switches
 - 2x 1000L top-up tanks
- Site Set-out
 - Earthing, Fuel bunding, Proximity to Sub, Volume



Photo: Generators installed at Scotland Street Quarry




Challenges

- Protection
 - Generator vs Network – System Modelling
 - Fault Current
 - Stalling
 - Back Feeding Zone Sub Tx
 - Over/Under Voltage on Gen Tx
 - CB108 Swap over
- Synchronising
 - Generator Loading Morning
 - Reverse Synchronising on Restore
 - Relay & SCADA control Commissioning. Voltage Matching VT
- MLL Gen fleet for voltage support at Spring Creek
- 11kV Line Upgrade between Sub and Gen Farm

Conclusion

- 47 Pole Sites Completed
- 3 Days vs 5 Days
- Approx. 22800L diesel
- 94270kWhs electricity
- Particularly Cold Mornings, exceeded N-1.
- 1 Network Fault & Protection Worked!
- DATA!!!



Thanks Team!



Questions?

Picton Loading – Generator & Network 30th April – 5th May 2017



Go Pro



Additional

