



Electrical Industry Health & Safety Group

Shared Learning

Reference to Critical Risk where appropriate



Actioned Improvement Opportunity

What happened?
During hot works and pentane pumping operations on site, fire extinguishers from the site workshop would be taken as part of the risk mitigation plan for these types of works.

Geothermal

What did we learn?
When the fire extinguishers from the workshop were taken to other work areas, the workshop was left without first response fire suppression equipment.

This observation prompted the site to purchase extinguishers specifically for hot works and pentane operations.

Having work specific fire extinguishers now means that extinguishers are not taken from other work areas that may need them should an emergency situation arise.

